



Change for the		Multi-Room Ductless systems		
Submittal Data: GTH(18)BA-D3DNA1A/I	18,000 BTU/H Universal	Floor/Ceiling Unit	
Job Name		Location	Date	
Purchaser		Engineer		
Submitted To		For Reference	Approval Construction	
Unit Designation		Schedule No.		
GENERAL FEATURES				
-Floor Stand or Ceiling Mount				
-Quiet Operation -Multi-Speed Fan			-	
-1-way Discharge Air Flow		Hillist		
-Swing Louvers		Ť		
-Wired and Wireless Remote Controller	S		GREE	
-Unlimited 10 yr. parts warranty -Without condensate pump		Grante Daniel	THE RESERVED THE PARTY NAMED IN	
-without condensate pump		Foreign W State Golden		
System Ra	tings	Physical Specifications		
Cooling*				
Rated Capacity	17,065 BTU/H	Unit Dimensions (LxHxD)	48.0 x 27.5 x 9.0 -ir	
Heating*			1220 x 700 x 225-mm	
Heating* Rated Capacity	18,772 BTU/H	Weight (Net/Shipping)	88/110 LBS	
Nated Capacity	10,772 010/11	Weight (New Shipping)	00/110 EBS	
Sound Level (Hi/Lo)**		Drain Size (OD)	0.67-ir	
Cooling	45/40 dbA		17-mm	
Heating	45/40 dbA			
Air Flow (max)				
Indoor Fan	559 CFM			
Electrical R	atings	Refrigerant Piping Data		
Fan Motor		Refrigerant Type	R410A	
Output Power	110 W	Con Din (Circ (CD)	4.0.1	
FLA	0.56 A	Gas Pipe Size (OD)	1/2-in	
Power Supply		Liquid Pipe Size (OD)	1/4-ir	
Normal Operational Voltage	208/230 V, 1 Phase, 60 Hz	Elquid 1 190 0120 (0D)	174-111	
Voltage Range	187 - 253 V	Connection Method	Flared	
MCA MCA	1.0 A		. 141.00	
Interconnecting Cable Wire Size	14-4 AWG			
,		* Test conditions are based on AH	RI 210/240.	
		**Sound Power ratings are per AH	RI 270 and AHRI 350	
R4IIOA	AUDI	CERTIFIED	(11)	








DIMENSIONAL SPECIFICATIONS

GTH(18)BA-D3DNA1A/I







Dimensions


(mm) (inches)


	Α	В	С	D	Н	Н
	1220	225	1158	280	700	700
)	48.0	8.9	45.6	11.0	27.6	27.6

Note: Size refrigerant lines based on evaporator port sizes.


MINIMUM CLEARANCE


♦ Wall type





Ceiling type





Notes:

- 1. Recommended Interconnecting Cable Type Stranded Bare Copper Conductors THHN 600V Unshielded Wire
- 2. Power wiring cable size must comply with applicable national and local codes.
- 3. Test conditions are based on AHRI 210/240.

